[redacted]

Van: [redacted]
Verzonden: dinsdag 1 mei 2018 15:54
Aan: [redacted]
Onderwerp: FW: Bouw evenenmentencomplex Rhoneweg Amsterdam
Bijlagen: [redacted]

Ha [redacted]

Ze bericht hieronder van de Gasunie, we hebben akkoord.

Groet,

[redacted]

DISCLAIMER: This message may contain confidential information. If you have received this e-mail in error please notify the sender immediately by e-mail and destroy this message. Any unauthorized copying, Disclosure or distribution of this message and/or attachments is not allowed. Internet communications cannot be guaranteed to be timely, secure, error or virus-free. The sender does not accept liability for any errors or omissions.

Van: [redacted]
Verzonden: dinsdag 1 mei 2018 15:47
Aan: [redacted]
CC: [redacted]
Onderwerp: Bouw evenenmentencomplex Rhoneweg Amsterdam

Betreft leiding: A-553-01-KR-016

Geachte [redacted]

Gasunie stemt onder de volgende voorwaarden in met de bouw van het evenementencomplex aan de Rhoneweg te Amsterdam.

- Bijgevoegde Velinvoorwaarden zijn van toepassing.
- De bebouwing dient buiten de belemmerende strook (2 keer 5 meter aan weerzijde van de leiding) te worden geplaatst.
- De hoogte van het maaiveld van de belemmerende strook wordt niet gewijzigd.
- Binnen de belemmerende strook wordt uitsluitend element verharding toegepast.

Ik ga ervan uit u hiermee voldoende te hebben geïnformeerd.

Met vriendelijke groet

[redacted]