

gevel S2 (achter tussenruimte: hal)

Su,gevel	2.8	m2		Cl	0.0	0.0	0.0	0.0	0.0	
GA;k,gevel	34.9	dB(A)								
GA,gevel	42.9	dB(A)		GA,g	42.9	52.2	54.6	56.2	47.9	46.3
Lp,gevel	24.0	dB(A)		Lp,g	24.0	14.7	12.3	10.7	19.0	20.6

Gvdeel	Afm.	Cat.nr.	Msoort	Materiaal	GA;k,p	GA;p	Cvlg		totaal	125	250	500	1000	2000
deur	1.76m2	de26	deur	Deur D1	46.2	54.2	--	RA	25.6	20.0	24.0	26.0	26.0	26.0
kier	5.96m	k20	kier	Geen dichting	35.3	43.3	--	RA	20.0	19.0	23.0	24.0	19.0	17.0
kozijn	0.44m2	ko31	kozijn	Kozijn K1	56.4	64.4	--	RA	30.7	22.0	25.0	33.0	35.0	35.0
naad	6.36m	na45	naad	Alleen lat	58.7	66.7	--	RA	44.7	35.0	40.0	45.0	50.0	60.0
wand	0.60m2	mw38	wand	Steenachtige wand 100 kg/m2	63.7	71.7	--	RA	38.1	32.0	35.0	36.0	40.0	46.0

slaapkamer S2

Su,ruimte	5.8	m2												
GA;k	38.0	dB(A)												
GA;k, vereist	31.9	dB(A)												
V	28.4	m3												
T,ref	0.5	s												
GA	40.1	dB(A)							GA	49.4	51.8	53.4	45.2	43.6
Lp	26.8	dB(A)							Lp	17.5	15.1	13.6	21.7	23.3

gevel S2 (achter tussenruimte: hal)

Su,gevel	5.8	m2		Cl	0.0	0.0	0.0	0.0	0.0	
GA;k,gevel	38.0	dB(A)								
GA,gevel	40.1	dB(A)		GA,g	40.1	49.4	51.8	53.4	45.2	43.6
Lp,gevel	26.8	dB(A)		Lp,g	26.8	17.5	15.1	13.6	21.7	23.3

Gvdeel	Afm.	Cat.nr.	Msoort	Materiaal	GA;k,p	GA;p	Cvlg		totaal	125	250	500	1000	2000
deur	1.76m2	de26	deur	Deur D1	49.3	51.5	--	RA	25.6	20.0	24.0	26.0	26.0	26.0
kier	5.96m	k20	kier	Geen dichting	38.4	40.6	--	RA	20.0	19.0	23.0	24.0	19.0	17.0
kozijn	0.44m2	ko31	kozijn	Kozijn K1	59.5	61.6	--	RA	30.7	22.0	25.0	33.0	35.0	35.0
naad	6.36m	na45	naad	Alleen lat	61.9	64.0	--	RA	44.7	35.0	40.0	45.0	50.0	60.0
wand	3.56m2	mw38	wand	Steenachtige wand 100 kg/m2	59.1	61.2	--	RA	38.1	32.0	35.0	36.0	40.0	46.0

slaapkamer S3

Su,ruimte	5.8	m2												
GA;k	38.0	dB(A)												
GA;k, vereist	33.9	dB(A)												
V	28.4	m3												
T,ref	0.5	s												
GA	40.1	dB(A)							GA	49.4	51.8	53.4	45.2	43.6
Lp	26.8	dB(A)							Lp	17.5	15.1	13.6	21.7	23.3

