

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Site   5.1.2,e 5.1.2,e	
Site name	5.1.2,e 5.1.2,e
1:FC721	
Customer text	
Element address	1
Internal status indication of detectors on C-NET	Disabled
External status indication of detectors on C-NET enabled	No
Template ID	104 -- Alarming RAC 10 zone ontruiming
Element ID	1/1
Ethernet MAC address	00:05:19:A0:A5:80
Licence	NOT PRESENT
SW version	61.0.66
GLOBAL alarming stopped by ACKN.	Internal sounder
LOCAL alarming stopped by ACKN.	Internal sounder
Enabled	No
Maintenance interval [months]	12
Fault message upon restart of station	No
BACnet notification - Element address	1
BACnet notification - Customer text	Bouwdelen
BACnet notification - BACnet object instance number	1
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/148
BACnet notification - Element address	2
BACnet notification - Customer text	Bouwdelen
BACnet notification - BACnet object instance number	2
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/440
BACnet notification - Element address	3
BACnet notification - Customer text	Groepen
BACnet notification - BACnet object instance number	3
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/225
BACnet notification - Element address	4
BACnet notification - Customer text	Sensoren
BACnet notification - BACnet object instance number	4
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/298
BACnet notification - Element address	5
BACnet notification - Customer text	Stuurgroepen
BACnet notification - BACnet object instance number	5
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/100
BACnet notification - Element address	6
BACnet notification - Customer text	Sturingen

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
BACnet notification - BACnet object instance number	6
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/65
BACnet notification - Element address	7
BACnet notification - Customer text	(Reserve)
BACnet notification - BACnet object instance number	7
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/390
BACnet notification - Element address	8
BACnet notification - Customer text	Kanalen (log.)
BACnet notification - BACnet object instance number	8
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/314
BACnet notification - Element address	9
BACnet notification - Customer text	Stations
BACnet notification - BACnet object instance number	9
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/239
BACnet notification - Element address	10
BACnet notification - Customer text	Module/Submodules
BACnet notification - BACnet object instance number	10
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/307
BACnet notification - Element address	11
BACnet notification - Customer text	Lussen
BACnet notification - BACnet object instance number	11
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/361
BACnet notification - Element address	12
BACnet notification - Customer text	Elementen
BACnet notification - BACnet object instance number	12
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/257
BACnet notification - Element address	13
BACnet notification - Customer text	Kanalen (phys.)
BACnet notification - BACnet object instance number	13
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/208

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
BACnet notification - Element address	14
BACnet notification - Customer text	Systeem
BACnet notification - BACnet object instance number	14
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/265
BACnet notification - Element address	15
BACnet notification - Customer text	UGA
BACnet notification - BACnet object instance number	15
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/374
BACnet notification - Element address	16
BACnet notification - Customer text	AVC
BACnet notification - BACnet object instance number	16
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/48
BACnet notification - Element address	17
BACnet notification - Customer text	IC
BACnet notification - BACnet object instance number	17
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/418
BACnet notification - Element address	18
BACnet notification - Customer text	Netwerk
BACnet notification - BACnet object instance number	18
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/164
BACnet notification - Element address	19
BACnet notification - Customer text	BACnet Client
BACnet notification - BACnet object instance number	19
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/322
BACnet notification - Element address	20
BACnet notification - Customer text	BACnet Device
BACnet notification - BACnet object instance number	20
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/118
BACnet notification - Element address	21
BACnet notification - Customer text	Line Summaries
BACnet notification - BACnet object instance number	21
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/44
BACnet notification - Element address	22
BACnet notification - Customer text	Section Summaries
BACnet notification - BACnet object instance number	22
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/121
BACnet notification - Element address	23
BACnet notification - Customer text	Brandklep stuurgroepen
BACnet notification - BACnet object instance number	23
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/174
BACnet notification - Element address	24
BACnet notification - Customer text	Brandklep sturingen
BACnet notification - BACnet object instance number	24
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/155
BACnet notification - Element address	25
BACnet notification - Customer text	Brandklep kanalen (phys.)
BACnet notification - BACnet object instance number	25
BACnet notification - Acknowledge required	Yes, Yes, No
BACnet notification - Event notification priorities	3, 3, 10
BACnet notification - Template ID	1 -- Standard
BACnet notification - Element ID	1/115
Cerberus-Remote - Customer text	Cerberus-Remote
Cerberus-Remote - Element address	1
Cerberus-Remote - Indicate permanent Cerberus-Remote access	No
Cerberus-Remote - Permanent Cerberus-Remote access	Full access (view/operation)
Cerberus-Remote - Template ID	1 -- Standard
Cerberus-Remote - Element ID	1/138
AVC/IC - Event category	Alle storingen
AVC/IC - Immediate intervention type 'manned'	Global intervention only
AVC/IC - Immediate intervention type 'unmanned'	Global intervention only
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Local alarming devices 'unmanned'	Internal sounder
AVC/IC - Global alarming devices 'unmanned'	RT Fault, Internal sounder
AVC/IC - Global alarming devices 'manned'	RT Fault, Internal sounder
AVC/IC - Local alarming devices 'manned'	Internal sounder
AVC/IC - Service intervention type 'manned'	Delayed intervention
AVC/IC - Service intervention type 'unmanned'	Delayed intervention
AVC/IC - ts	23:00:00
AVC/IC - Alarming devices 'Service Intervention'	RT Fault
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/47
AVC/IC - Event category	Alle uitschakelingen
AVC/IC - Immediate intervention type 'manned'	Disabled
AVC/IC - Immediate intervention type 'unmanned'	Disabled
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
AVC/IC - Service intervention type 'manned'	Disabled
AVC/IC - Service intervention type 'unmanned'	Disabled
AVC/IC - ts	03:00:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/354
AVC/IC - Event category	Alle testmeldingen
AVC/IC - Immediate intervention type 'manned'	Disabled
AVC/IC - Immediate intervention type 'unmanned'	Disabled
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Service intervention type 'manned'	Disabled
AVC/IC - Service intervention type 'unmanned'	Disabled
AVC/IC - ts	03:00:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/289
AVC/IC - Event category	Alle techniekmeldingen
AVC/IC - Immediate intervention type 'manned'	Disabled
AVC/IC - Immediate intervention type 'unmanned'	Disabled
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Service intervention type 'manned'	Disabled
AVC/IC - Service intervention type 'unmanned'	Disabled
AVC/IC - ts	03:00:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/340
AVC/IC - Event category	Alle activeringen
AVC/IC - Immediate intervention type 'manned'	Disabled
AVC/IC - Immediate intervention type 'unmanned'	Disabled
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Service intervention type 'manned'	Disabled
AVC/IC - Service intervention type 'unmanned'	Disabled
AVC/IC - ts	03:00:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/387
AVC/IC - Event category	Alle informatiemeldingen
AVC/IC - Immediate intervention type 'manned'	Disabled
AVC/IC - Immediate intervention type 'unmanned'	Disabled
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Service intervention type 'manned'	Disabled
AVC/IC - Service intervention type 'unmanned'	Disabled
AVC/IC - ts	03:00:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/306
Cerberus-Remote: full access temporarily enabled (view/operation) - Event text	Bedien.(tijdelijk)
Cerberus-Remote: full access temporarily enabled (view/operation) - Event category	Systeem informatie
Cerberus-Remote: view access temporarily enabled - Event text	View (tijdelijk)
Cerberus-Remote: view access temporarily enabled - Event category	Systeem informatie
Cerberus-Remote connected - Event text	C-Remote verbonden
Cerberus-Remote connected - Event category	Systeem informatie
Cerberus-Remote: full access permanently enabled (view/operation) - Event text	Bedien.(permanent)
Cerberus-Remote: full access permanently enabled (view/operation) - Event category	Systeem informatie
Cerberus-Remote: view access permanently enabled - Event text	Viewer (permanent)

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Cerberus-Remote: view access permanently enabled - Event category	Systeem informatie
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Time synchronization lost - Event text	Geen synch. puls
Time synchronization lost - Event category	--Storing overig
Configuration data corrupt - Event text	Configur. corrupt!
Configuration data corrupt - Event category	----Overige systeem storingen
Station restarted - Event text	Station herstart
Station restarted - Event category	----Overige systeem storingen
Wrong station type (HW configuration mismatch) - Event text	Verkeerd stat.type
Wrong station type (HW configuration mismatch) - Event category	----Overige systeem storingen
System startup completed - Event text	Startup voltooid
System startup completed - Event category	Systeem informatie
Factory reset (with S38-1 in active position) - Event text	Fabrieksinstelling
Factory reset (with S38-1 in active position) - Event category	Systeem informatie
No configuration data (pre-configuration loaded) - Event text	Geen config. data!
No configuration data (pre-configuration loaded) - Event category	----Overige systeem storingen
MC link enabled - Event text	MCLink vrijgegeven
MC link enabled - Event category	Systeem informatie
System time lost - Event text	Geen sync.Sys.tijd
System time lost - Event category	Systeem informatie
Time master unavailable - Event text	Geen verb.Timemstr
Time master unavailable - Event category	Systeem informatie
System analyzer enabled - Event text	Systeemanalyse aan
System analyzer enabled - Event category	Systeem informatie
Software redundancy - Event text	Beperkte functies
Software redundancy - Event category	----Overige systeem storingen
Maintenance due (maintenance interval expired) - Event text	Onderhoud nodig
Maintenance due (maintenance interval expired) - Event category	--Service informatie: Service nodig
Buzzer - Customer text	Zoemer
Buzzer - Element address	1
Buzzer - Disable operating terminal buzzer while Cerberus-Remote is active	Yes
Buzzer - Template ID	1 -- Standard
Buzzer - Element ID	1/15
 1:Detection area   5.1.2,e	
Element address	1
Customer text	5.1.2,e
Plan no.	0
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	17:00
Enabled	Yes
Enabled	Yes
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	20:00
Enabled	Yes
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	22:00
Enabled	Yes
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	23:45
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Time	20:00
Enabled	No
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	20:30
Time	21:00
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	21:30
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	22:00
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Enabled	No
Time	22:30
Template ID	1 -- Standaard
Element ID	1/142
Immediate global alarming	- (disabled)
Alarm organization mode	Always unmanned (no messages/no LED/no switching fct.)
AVC/IC - Event category	--Alle Brand ALARMEN
AVC/IC - GLOBAL alarming stopped by ACKN.	Internal sounder
AVC/IC - LOCAL alarming stopped by ACKN.	Internal sounder
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:01:00
AVC/IC - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/405
AVC/IC - Event category	Alle Waarschuwingen
AVC/IC - GLOBAL alarming stopped by ACKN.	Internal sounder
AVC/IC - LOCAL alarming stopped by ACKN.	Internal sounder
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:03:00
AVC/IC - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/92
AVC/IC - Event category	--Alle Gas ALARMEN
AVC/IC - GLOBAL alarming stopped by ACKN.	Internal sounder
AVC/IC - LOCAL alarming stopped by ACKN.	Internal sounder
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:03:00
AVC/IC - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/64
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Manned operation - Event text	Dagsituatie
Manned operation - Event category	--Dagsituatie
Unmanned operation - Event text	Nachtsituatie
Unmanned operation - Event category	--Nachtsituatie

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Fire related controls OFF (for this area) - Event text	Brandsturingen UIT
Fire related controls OFF (for this area) - Event category	--Brandsturingen UIT
Sounders OFF (for this area) - Event text	Alarmgevers UIT
Sounders OFF (for this area) - Event category	--Alarmgevers UIT
Remote transmission channels FIRE OFF (for this area) - Event text	Doorm.kanalen UIT
Remote transmission channels FIRE OFF (for this area) - Event category	--RT BRAND kanalen UIT
AVC/IC stopped - Event text	Doormeldvertr. UIT
AVC/IC stopped - Event category	Informatie: AVC/IC gestopt
AVC/IC stopped - Event text	Doormeldvertr. UIT
AVC/IC stopped - Event category	Informatie: AVC/IC gestopt
AVC/IC stopped - Event text	Doormeldvertr. UIT
AVC/IC stopped - Event category	Informatie: AVC/IC gestopt
AVC configuration - Event category	----Alle autom. Brand ALARMEN
AVC configuration - Alarming type 'unmanned'	Global alarming only
AVC configuration - Alarming type 'manned'	Delayed alarming
AVC configuration - Global alarming devices 'unmanned'	RT 1
AVC configuration - Global alarming devices 'manned'	RT 1
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/176
AVC configuration - Event category	----Handmatig Brand ALARM
AVC configuration - Alarming type 'unmanned'	Global alarming only
AVC configuration - Alarming type 'manned'	Global alarming only
AVC configuration - Global alarming devices 'unmanned'	RT Fire
AVC configuration - Global alarming devices 'manned'	RT Fire
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/349
AVC configuration - Event category	--Waarschuwing, brand
AVC configuration - Alarming type 'unmanned'	Local alarming only
AVC configuration - Alarming type 'manned'	Local alarming only
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/16
AVC configuration - Event category	----CO gas ALARM
AVC configuration - Alarming type 'unmanned'	Local alarming only
AVC configuration - Alarming type 'manned'	Local alarming only
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/197
 1:Section   1   Zone 1 : 5.1.2.e 512 Trappenhuis	
Element address	1
Customer text	Zone 1 : 5.1.2.e 512 Trappenhuis
Plan no.	1
Template ID	1 -- Standaard
Element ID	1/956
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/955
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 1:Automatic zone   1   Meterkast	
Element address	1
Customer text	Meterkast
Plan no.	1
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/988
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/992
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\3:OP720\2:Sensor
 2:Automatic zone   2   Gang	
Element address	2
Customer text	Gang
Plan no.	2
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/989
Channel activation	In PRE-STAGE and MAIN STAGE

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/994
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\4:OP720\2:Sensor
 4:Automatic zone    Centrale hal    5.1.2.e	
Element address	
Customer text	Centrale hal  5.1.2.e
Plan no.	
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1001
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1003
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\9:OP720\2:Sensor
 7:Automatic zone   7   Centrale hal <small>5.1.2.e</small>	
<small>5.1.2.e</small> Element address	7
Customer text	Centrale hal <small>5.1.2.e</small> <small>5.1.2.e</small>
Plan no.	7
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1012
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1014
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\117:OP720\2:Sensor
 10:Manual zone   10   Trapopgang	
Element address	10
Customer text	Trapopgang
Plan no.	10
Intervention text	
Template ID	1 -- Standaard
Element ID	1/1052
OFF allowed	Yes
Always resettable	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Handm.BRANDALARM
MAIN STAGE - Event category	----Handmatig Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Global alarming only
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT Fire
MAIN STAGE - Global alarming devices 'manned'	RT Fire
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:FDM225/226/Sensor	

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1053
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\5:FDM225/226\1:Sensor
 ← 2:FDM225/226/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1054
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\10:FDM225/226\1:Sensor
 3:FDM225/226/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1055
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\18:FDM225/226\1:Sensor
 2:Section   2   Zone 2 : 5.1.2.e 5.1.2.e	
Element address	2
Customer text	Zone 2 : 5.1.2.e 5.1.2.e
Plan no.	2
Template ID	1 -- Standaard
Element ID	1/958
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/957
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 3:Section   3   Zone 3 : 5.1.2.e 5.1.2.e	
Element address	3
Customer text	Zone 3 : 5.1.2.e 5.1.2.e
Plan no.	3
Template ID	1 -- Standaard
Element ID	1/960
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/959
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 3:Automatic zone   3   <span>5.1.2,e</span> <span>5.1.2,e</span>	
Element address	3
Customer text	<span>5.1.2,e</span> <span>5.1.2,e</span>
Plan no.	3
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/990
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/996
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\6:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Template ID	1 -- Standaard
Element ID	1/998
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\7:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1000
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\8:OH720\2:Sensor
 5:Automatic zone   5   <span style="background-color: #cccccc;">5.1.2,e</span> <span style="background-color: #cccccc;">5.1.2,e</span>	
Element address	5
Customer text	<span style="background-color: #cccccc;">5.1.2,e</span> <span style="background-color: #cccccc;">5.1.2,e</span>
Plan no.	5
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1004
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1006
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\11:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1008
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\12:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1010
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721 2:C-NET line card (onboard/FCL2001) 1:Loop 1 1/1 2 13:OH720 2:Sensor
 4:Section   4   Zone  :  5.1.2,e	
Element address	4
Customer text	Zone  :  5.1.2,e
Plan no.	4
Template ID	1 -- Standaard
Element ID	1/962
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/961
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 6:Automatic zone   6    5.1.2,e	
Element address	6
Customer text	 5.1.2,e
Plan no.	6
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1011
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1016
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC7212:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\14:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1018
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\15:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1020
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\16:OH720\2:Sensor
 8:Automatic zone   8   <small>5.1.2.e</small> <small>5.1.2.e</small>	
Element address	8
Customer text	<small>5.1.2.e</small> <small>5.1.2.e</small>
Plan no.	8
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1021
Channel activation	In PRE-STAGE and MAIN STAGE

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1023
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\19:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1025
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\20:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1027
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\21:OH720\2:Sensor
 5:Section   5   Zone 5 : 5.1.2.e 5.1.2.e 5.1.2.e	
Element address	5
Customer text	Zone 5 : 5.1.2.e 5.1.2.e 5.1.2.e
Plan no.	5
Template ID	1 -- Standaard
Element ID	1/964
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/963
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 9:Automatic zone   9   5.1.2.e 5.1.2.e	
Element address	9
Customer text	5.1.2.e 5.1.2.e
Plan no.	9
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1028
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1030
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet



Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\22:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1032
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\23:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1034
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\24:OH720\2:Sensor
 6:Section   6   Zone 6 : 5.1.2.e 6 Trapopgang	
Element address	6
Customer text	Zone 6 : 5.1.2.e 6 Trapopgang
Plan no.	6
Template ID	1 -- Standaard
Element ID	1/966
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/965
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 13:Automatic zone   13   Centrale hal 5.1.2.e	
Element address	13
Customer text	Centrale hal 5.1.2.e
Plan no.	13
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1058
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1081
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\31:OP720\2:Sensor
 16:Automatic zone   16   Centrale hal 	
Element address	16
Customer text	Centrale hal 
Plan no.	16
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1061
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1097
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1_1\1_2\39:OP720\2:Sensor
 18:Automatic zone   18   Gang	
Element address	18
Customer text	Gang
Plan no.	18
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1063
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1105
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC72112:C-NET line card (onboard/FCL2001)1:Loop 1 1/1_2145:OP72012:Sensor
 19:Automatic zone   19   Meterkast	

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Element address	19
Customer text	Meterkast
Plan no.	19
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1064
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARMS
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslijm
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1107
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\46:OP720\2:Sensor
 20:Manual zone   20   Trapopgang	
Element address	20
Customer text	Trapopgang
Plan no.	20
Intervention text	
Template ID	1 -- Standaard
Element ID	1/1108
OFF allowed	Yes
Always resettable	Yes
Timeout detector/walk test	01:00
Enabled	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Criteria MAIN STAGE	0, 1
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Handm.BRANDALARM
MAIN STAGE - Event category	---Handmatig Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Global alarming only
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT Fire
MAIN STAGE - Global alarming devices 'manned'	RT Fire
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:FDM225/226/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1109
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\32:FDM225/226\1:Sensor
 ← 2:FDM225/226/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1110
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\40:FDM225/226\1:Sensor
 3:FDM225/226/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1111
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\44:FDM225/226\1:Sensor
  7:Section   7   Zone 7 : 	
Element address	7
Customer text	Zone 7 : 
Plan no.	7
Template ID	1 -- Standaard
Element ID	1/968
Section summary - BACnet object name	

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/967
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 8:Section   8   Zone 8 : 5.1,2,e 5.1,2,e	
Element address	8
Customer text	Zone 8 : 5.1,2,e 5.1,2,e
Plan no.	8
Template ID	1 -- Standaard
Element ID	1/970
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/969
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 15:Automatic zone   15   5.1,2,e 5.1,2,e	
Element address	15
Customer text	5.1,2,e 5.1,2,e
Plan no.	15
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1060
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1091
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\36:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1093
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1_1\1_2\37:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1095
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\38:OH720\2:Sensor
 17:Automatic zone   17   5.1.2,e 5.1.2,e	
Element address	17
Customer text	5.1.2,e 5.1.2,e
Plan no.	17
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1062
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1099
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\41:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1101
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\42:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1103
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\43:OH720\2:Sensor
 9:Section   9   Zone 9 : 5.1.2,e 5.1.2,e 5.1.2,e	
Element address	9
Customer text	Zone 9 : 5.1.2,e 5.1.2,e 5.1.2,e
Plan no.	9
Template ID	1 -- Standaard
Element ID	1/972
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/971
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 12:Automatic zone   12   5.1.2,e 5.1.2,e	
Element address	12
Customer text	5.1.2,e 5.1.2,e
Plan no.	12
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1057
Channel activation	In PRE-STAGE and MAIN STAGE

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1075
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\28:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1077
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\29:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1079
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\30:OH720\2:Sensor
 14:Automatic zone   14   5.1.2,e	
Element address	14
Customer text	5.1.2,e
Plan no.	14
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1059
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1083
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\33:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1085
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\34:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Element address	3
Template ID	1 -- Standaard
Element ID	1/1087
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\35:OH720\2:Sensor
 10:Section   10   Zone 10 : 5.1.2.e 5.1.2.e 5.1.2.e	
Element address	10
Customer text	Zone 10 : 5.1.2.e 5.1.2.e 5.1.2.e
Plan no.	10
Template ID	1 -- Standaard
Element ID	1/974
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/973
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 11:Automatic zone   11   <small>5.1.2,e 5.1.2,e</small>	
Element address	11
Customer text	<small>5.1.2,e 5.1.2,e</small>
Plan no.	11
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1056
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode





Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1069
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\25:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Template ID	1 -- Standaard
Element ID	1/1071
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\26:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1073
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC7212:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\27:OH720\2:Sensor
 11:Section   11   Zone 11 :  Trappenhuis	
Element address	11
Customer text	Zone 11 :  Trappenhuis
Plan no.	11
Template ID	1 -- Standaard
Element ID	1/976
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/975
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 21:Automatic zone   21   Meterkast	
Element address	21
Customer text	Meterkast

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Plan no.	21
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1125
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Template ID	1 -- Standaard
Element ID	1/1136
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\49:OP720\2:Sensor
 22:Automatic zone   22   Gang	
Element address	22
Customer text	Gang
Plan no.	22
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1126
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1138
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed




Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\150:OP720\2:Sensor
 24:Automatic zone   24   Centrale hal 	
 5.1.2,e	
Element address	24
Customer text	Centrale hal  5.1.2,e
Plan no.	24
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1128
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1146
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.



Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\55:OP720\2:Sensor
 27:Automatic zone   27   Centrale hal 	
	
Element address	27
Customer text	Centrale hal  
Plan no.	27
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1131
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1161
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\63:OP720\2:Sensor
 30:Manual zone   30   Trappenhuis	
Element address	30
Customer text	Trappenhuis
Plan no.	30
Intervention text	
Template ID	1 -- Standaard
Element ID	1/1174
OFF allowed	Yes
Always resettable	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Handm.BRANDALARM
MAIN STAGE - Event category	----Handmatig Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Global alarming only
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT Fire
MAIN STAGE - Global alarming devices 'manned'	RT Fire
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:FDM225/226/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1175



Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC72112:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2151:FDM225/226\1:Sensor
 2:FDM225/226/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1176
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\56:FDM225/226\1:Sensor
 ← 3:FDM225/226/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1177
Replace mode active - Event text	Vervangings mode
Replace mode active - Event category	Systeem informatie
Glass broken - Event text	Glas gebroken
Glass broken - Event category	--Storing overig
Door open - Event text	Deur open
Door open - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 /1/ 2\64:FDM225/226\1:Sensor
 12:Section   12   Zone 12 : 	
Element address	12
Customer text	Zone 12 : 
Plan no.	12
Template ID	1 -- Standaard
Element ID	1/978
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/977
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 13:Section   13   Zone 13 : 	
Element address	13
Customer text	Zone 13 : 
Plan no.	13
Template ID	1 -- Standaard
Element ID	1/980
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/979
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 23:Automatic zone   23   5.1.2,e 5.1.2,e	
Element address	23
Customer text	5.1.2,e 5.1.2,e
Plan no.	23
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1127
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1140
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\52:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1142
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\53:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1144
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\54:OH720\2:Sensor
 25:Automatic zone   25   <small>5.1.2.e</small>   <small>512e</small>	
Element address	25
Customer text	<small>5.1.2.e</small>   <small>512e</small>
Plan no.	25
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1129
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00



Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1148
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\57:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1150
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\58:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1152
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\59:OH720\2:Sensor
 14:Section   14   Zone 14 :   	
Element address	14

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Customer text	Zone 14 : 5.1,2,e 5.1,2,e 5.1,2,e
Plan no.	14
Template ID	1 -- Standaard
Element ID	1/982
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/981
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 26:Automatic zone   26   5.1,2,e 5.1,2,e	
Element address	26
Customer text	5.1,2,e 5.1,2,e
Plan no.	26
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1130
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARMS
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1155
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\60:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1157
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\61:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Template ID	1 -- Standaard
Element ID	1/1159
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\62:OH720\2:Sensor
 28:Automatic zone   28   <small>5.1.2,e</small> <small>5.1.2,e</small>	
Element address	28
Customer text	<small>5.1.2,e</small> <small>5.1.2,e</small>
Plan no.	28
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1132
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1163
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed







Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1_2\65:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1165
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\66:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1167
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC7212:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\67:OH720\2:Sensor
 15:Section   15   Zone 15 : 	
Element address	15
Customer text	Zone 15 : 
Plan no.	15
Template ID	1 -- Standaard
Element ID	1/984
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/983
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 29:Automatic zone   29   	
Element address	29
Customer text	
Plan no.	29
Intervention text	
Template ID	1 -- Single, Standaard t2=5min
Element ID	1/1133
Channel activation	In PRE-STAGE and MAIN STAGE
External AI activation	In PRE-STAGE and MAIN STAGE
Base sounder activation	In MAIN STAGE only
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Criteria PRE-STAGE	1, 0
Additional criteria for PRE-/MAIN STAGE	Fallback to single detector/zone dependency
Two-zone dependency	No
Multi detector dependency with latching	No
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Autom.BRANDALARM
MAIN STAGE - Event category	-----Algemeen autom. Brand ALARM
MAIN STAGE - Use individual AVC settings	No

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
MAIN STAGE - Alarming type 'unmanned'	Global alarming only
MAIN STAGE - Alarming type 'manned'	Delayed alarming
MAIN STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
MAIN STAGE - Global alarming devices 'unmanned'	RT 1
MAIN STAGE - Global alarming devices 'manned'	RT 1
PRE-STAGE - Event text	Waarschuwing
PRE-STAGE - Event category	--Waarschuwing, brand
PRE-STAGE - Use individual AVC settings	No
PRE-STAGE - Alarming type 'unmanned'	Local alarming only
PRE-STAGE - Alarming type 'manned'	Local alarming only
PRE-STAGE - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Renovation mode - Event text	Renovatie mode
Renovation mode - Event category	--Renovatie mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:OP720/Sensor	
Customer text	
Element address	1
Template ID	1 -- Standaard
Element ID	1/1169
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\68:OP720\2:Sensor
 2:OP720/Sensor	
Customer text	
Element address	2
Template ID	1 -- Standaard
Element ID	1/1171
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC7212:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\69:OP720\2:Sensor
 3:OH720/Sensor	
Customer text	
Element address	3
Template ID	1 -- Standaard
Element ID	1/1173
Base sounder configuration fault - Event text	Base snd. config.
Base sounder configuration fault - Event category	--Storing overig
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
Exchange of device required - Event text	Bereik 100
Exchange of device required - Event category	--Service informatie: Service nodig
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1 2\70:OH720\2:Sensor
 16:Section   16   Zone 16 : Voedingen	
Element address	16
Customer text	Zone 16 : Voedingen
Plan no.	16
Template ID	1 -- Standaard
Element ID	1/987
Section summary - BACnet object name	
Section summary - Template ID	1 -- Standard
Section summary - Element ID	1/986
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
Alarm summary - Event text	Alarm overzicht
Alarm summary - Event category	--Overige informatie
 31:Technical zone   31   Storing voeding <span style="background-color: #cccccc; color: #000000; font-size: 8px;">5.1.2.e</span>	
Element address	31
Customer text	Storing voeding <span style="background-color: #cccccc; color: #000000; font-size: 8px;">5.1.2.e</span>
Plan no.	31
Intervention text	
Template ID	101 -- Standaard Storing
Element ID	1/1178
External AI activation	- (no activation)
Base sounder activation	- (no activation)
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Storing
MAIN STAGE - Event category	--Storing overig
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie


Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
 1:FDCI221/Input/Input	
Customer text	
Element address	1
Evaluation filter time	00:00:03
Template ID	1 -- Standaard
Element ID	1/1288
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
Battery low - Event text	Accuspanning laag
Battery low - Event category	--Service informatie: Service nodig
Weak radio connection - Event text	Geen redundant pad
Weak radio connection - Enabled	Yes
Weak radio connection - Event category	Systeem informatie
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1_1/1_2\2:FDCI221\11:Input
 32:Technical zone   32   Storing voeding <span style="background-color: #cccccc;">5.1.2,e</span>	
Element address	32
Customer text	Storing voeding <span style="background-color: #cccccc;">5.1.2,e</span>
Plan no.	32
Intervention text	
Template ID	101 -- Standaard Storing
Element ID	1/1179
External AI activation	- (no activation)

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Base sounder activation	- (no activation)
OFF allowed	Yes
Timeout detector/walk test	01:00
Enabled	No
Criteria MAIN STAGE	0, 1
Reset time	00:01:00
Enabled	No
MAIN STAGE - Event text	Storing
MAIN STAGE - Event category	--Storing overig
Installation test mode - Event text	Install.test mode
Installation test mode - Event category	--Installatietest mode
Alarm evaluation OFF - Event text	Alarm evaluat. UIT
Alarm evaluation OFF - Event category	--Alarm evaluatie UIT
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Walk test mode - Event text	Walk test mode
Walk test mode - Event category	--Walk test mode
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Multi detector dependency off - Event text	Meer meld.afh.uit
Multi detector dependency off - Event category	--Overige informatie
 1:FDCI221/Input/Input	
Customer text	
Element address	1
Evaluation filter time	00:00:03
Template ID	1 -- Standaard
Element ID	1/1289
Exchange of device recommended - Event text	Bereik 100
Exchange of device recommended - Event category	--Service informatie: Service nodig
OFF - Event text	UIT
OFF - Event category	--Overige systeemdelen uit
OFF, duration limited - Event text	UIT, tijdslimiet
OFF, duration limited - Event category	--Tijdelijk uitgeschakeld
Period of time limited isolation expires - Event text	Tijd UIT verloopt
Period of time limited isolation expires - Event category	--Verstrijken herinner. tijdel. uitschak.
Active - Event text	Actief
Active - Enabled	Yes
Active - Event category	--Overige activering
Test activation - Event text	Test activering
Test activation - Event category	--Overige testactivering
Detector test mode - Event text	Meldertest mode
Detector test mode - Event category	--Meldertest mode
Not ready - Event text	Niet gereed
Not ready - Event category	--Niet gereed
Battery low - Event text	Accuspanning laag
Battery low - Event category	--Service informatie: Service nodig
Weak radio connection - Event text	Geen redundant pad

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Weak radio connection - Enabled	Yes
Weak radio connection - Event category	Systeem informatie
Fault - Event text	Storing
Fault - Event category	--Storing overig
Device location fault - Event text	Elem.lokatie fout
Device location fault - Event category	--Storing overig
Device missing - Event text	Element ontbreekt
Device missing - Event category	--Storing overig
Configuration fault - Event text	Configuratie fout
Configuration fault - Event category	--Storing overig
Noise on detector line - Event text	Ruis op de lus
Noise on detector line - Event category	Overige service informatie
Line isolator open - Event text	Lusscheider open
Line isolator open - Event category	Systeem informatie
Next to open line - Event text	Naast onderbr. lus
Next to open line - Event category	Systeem informatie
Hyperlink	Site\1:FC721\2:C-NET line card (onboard/FCL2001)\1:Loop 1 1/1_2\48:FDCI221\11:Input
 10:Station area	
Element address	10
Customer text	
Plan no.	0
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	17:00
Enabled	Yes
Enabled	Yes
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	20:00
Enabled	Yes
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	22:00
Enabled	Yes
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	23:45
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	20:00
Enabled	No
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	20:30
Time	21:00
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	21:30
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Time	22:00
Enabled	No
Days of the week	Monday, Tuesday, Wednesday, Thursday, Friday, Saturday, Sunday
Enabled	No
Time	22:30
Template ID	1 -- Standaard
Element ID	1/211

Detection tree - Node report - from Site to Logical channel  
12 sep 2018 14:21:19

Detection tree	Value
Immediate global alarming	- (disabled)
Alarm organization mode	Always unmanned (no messages/no LED/no switching fct.)
AVC/IC - Event category	--Alle Brand ALARMEN
AVC/IC - GLOBAL alarming stopped by ACKN.	Internal sounder
AVC/IC - LOCAL alarming stopped by ACKN.	Internal sounder
AVC/IC - t1 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:01:00
AVC/IC - t2 [EN54-2: t1+t2 of AVC=max. 10 min.]	00:05:00
AVC/IC - Template ID	1 -- Standard
AVC/IC - Element ID	1/28
Manned operation - Event text	Dagsituatie
Manned operation - Event category	--Dagsituatie
Unmanned operation - Event text	Nachtsituatie
Unmanned operation - Event category	--Nachtsituatie
Fire related controls OFF (for this area) - Event text	Brandsturingen UIT
Fire related controls OFF (for this area) - Event category	--Brandsturingen UIT
Sounders OFF (for this area) - Event text	Alarmgevers UIT
Sounders OFF (for this area) - Event category	--Alarmgevers UIT
Remote transmission channels FIRE OFF (for this area) - Event text	Doorm.kanalen UIT
Remote transmission channels FIRE OFF (for this area) - Event category	--RT BRAND kanalen UIT
AVC/IC stopped - Event text	Doormeldvertr. UIT
AVC/IC stopped - Event category	Informatie: AVC/IC gestopt
AVC configuration - Event category	----Alle autom. Brand ALARMEN
AVC configuration - Alarming type 'unmanned'	Global alarming only
AVC configuration - Alarming type 'manned'	Delayed alarming
AVC configuration - Global alarming devices 'unmanned'	RT 1
AVC configuration - Global alarming devices 'manned'	RT 1
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/231
AVC configuration - Event category	----Handmatig Brand ALARM
AVC configuration - Alarming type 'unmanned'	Global alarming only
AVC configuration - Alarming type 'manned'	Global alarming only
AVC configuration - Global alarming devices 'unmanned'	RT Fire
AVC configuration - Global alarming devices 'manned'	RT Fire
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/9
AVC configuration - Event category	----Noodbedrijf Brand ALARM
AVC configuration - Alarming type 'unmanned'	Global alarming only
AVC configuration - Alarming type 'manned'	Global alarming only
AVC configuration - Global alarming devices 'unmanned'	RT Fire
AVC configuration - Global alarming devices 'manned'	RT Fire
AVC configuration - Template ID	1 -- Standard
AVC configuration - Element ID	1/165